

# 2024 Annual Drinking Water Quality Report

## (Consumer Confidence Report)

Harris County WCID #99  
PWSID #1010684

### OUR DRINKING WATER IS REGULATED

This report is a summary of the quality of the water we provide our customers. The analysis was made by using the data from the most recent U.S. Environmental Protection Agency (EPA) required tests and is presented in the attached pages. We hope this information helps you become more knowledgeable about what's in your drinking water.

### Source of Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals, and in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water before treatment include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

### SPECIAL NOTICE

#### Required language for ALL community Public water supplies:

You may be more vulnerable than the general population to certain microbial contaminants, such as Cryptosporidium, in drinking water. Infants, some elderly or immunocompromised persons such as those undergoing chemotherapy for cancer; those who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care provider. Additional guidelines on appropriate means to lessen the risk of infection by Cryptosporidium are available from the Safe Drinking Water Hotline at (800) 426-4791.

### Harris County WCID #99

#### Board of Directors Message

The Board of Directors of Harris County WCID #99 is pleased to give you this report about our drinking water based on 2024 test results. The District is required by the Federal Safe Drinking Water Act to send the report each year. The content of the report is specified by the State of Texas. If you have any difficulties in reading or understanding the report, please call our operator at the number below. **The Board believes that the most important information contained in the Report is that the District's water supply was found to meet the requirements set by the State and Federal government for drinking water.**

Please call the District's operator, Eagle Water Management, Inc. at 281-374-8989 if you have any questions regarding this report.

### En Español

Este reporte incluye información importante sobre el agua para tomar. Para asistencia en español, favor de llamar al telefono (281) 374-8989.

### Where do we get our drinking water?

Our drinking water is obtained from GROUND water sources. It comes from the following Aquifers: Evangeline and Chicot located in Harris County. In addition, the District maintains interconnects with Harris County WCID 110 for use in an emergency. For additional information on this water source contact the Districts operator at 281-374-8989. The Texas Commission on Environmental Quality completed an assessment of your source water and results indicate that some of your sources are susceptible to certain contaminants. The sampling requirements for your water system are based on this susceptibility and previous sample data. Any detections of these contaminants may be found in this Consumer Confidence Report. For more information on source water assessments and protection efforts at our system, please contact the Districts operator, Eagle Water Management, Inc. at 281-374-8989. For more information about your sources of water, please refer to the Source Water Assessment Viewer available at the following <http://www.tceq.texas.gov/gis/swaview>. Further details about sources and source-water assessments are available in Drinking Water Watch at <http://dww2.tceq.texas.gov/DWW/>.

### ALL drinking water may contain contaminants.

When drinking water meets federal standards there may not be any health based benefits to purchasing bottled water or point of use devices. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (1-800-426-4791).

### Secondary Constituents

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health. Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the District's operator at 281-374-8989.

### About The Following Pages

The pages that follow list all of the federally regulated or monitored contaminants which have been found in your drinking water.

### 2024 Water Loss Audit

In the water loss audit submitted to the Texas Water Development Board for the time period of Jan – Dec 2024, our system lost an estimated 6,966,935 gallons of water. If you have any questions about the water loss audit, please call 281-374-8989.

### Public Meetings

The Board meets on the third Tuesday of each month at 6:00 P.M... The meetings are held at 19423 Lockridge, Spring, Texas. For additional information regarding the meeting call 281-374-8989. You may mail comments to:  
Harris County WCID #99  
Attn: Board of Directors  
P.O. Box 11750  
Spring, Texas 77391-1750

Inorganic Contaminants

Year or Range	Contaminant	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Violation	Unit of Measure	Source of Contaminant
10/19/2022	Arsenic*	4.5	4.5 – 4.5	0	10	No	ppb	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes.
10/19/2022	Barium	0.299	0.299–0.299	2	2	No	ppm	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits.
2024	Fluoride	0.11	0.11 – 0.11	4	4	No	ppm	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories.
2024	Nitrate (measured as Nitrogen)	0.22	0.22 – 0.22	10	10	No	ppm	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.

Required Additional Health Information for Arsenic

"While your drinking water meets EPA's standard for arsenic, it does contain low levels of arsenic. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems."

Radioactive contaminants

Year	Contaminant	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Unit of Measure	Violation	Source of Contaminant
2024	Gross alpha excluding radon and uranium	3.2	3.2 – 3.2	0	15	pCi/L	No	Erosion of natural deposits.

\*EPA considers 50 pCi/L to be the level of concern for beta particles.

Disinfectants and Disinfection Byproducts

Year	Contaminant	**Highest Level Detected	Range of Levels Detected	MCLG	MCL	Unit of Measure	Violation	Source of Contaminant
2024	Trihalomethanes (TTHM)	3	0 – 2.7	No Goal for the total	80	ppb	No	By-product of drinking water disinfection

"The value in the Highest Level or Average Detected column is the highest average of all TTHM or HAA5 sample results collected at a location over a year"

Maximum Residual Disinfectant Level

Year or Range	Disinfectant	Average Level	Minimum Level	Maximum Level	MRDL	MRDLG	Unit of Measure	Source of Disinfectant
2024	Chlorine Residual, Free	1.69	1.00	2.20	4	4	ppm	Water additive used to control microbes.

Lead and Copper

Definitions:

Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Year	Contaminant	90 <sup>th</sup> Percentile	Number of Sites Over Action Level	Action Level	MCLG	Unit of Measure	Violation	Source of Contaminant
2024	Lead	0	0	15	0	ppb	No	Corrosion of household plumbing systems; erosion of natural deposits.
2024	Copper	0.0919	0	1.3	1.3	ppm	No	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.

Required Additional Health Information for Lead

"If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. This water supply is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>."

DEFINITIONS

**Maximum Contaminant Level (MCL)**  
The highest permissible level of a contaminant in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal (MCLG)**  
The level of a contaminant in drinking water below which there is no known or expected health risk. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL)**  
The highest level of disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Level 1 Assessment**  
A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

**Level 2 Assessment**  
A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions

**Maximum Residual Disinfectant Level Goal (MRDLG)**  
The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

**Action Level (AL)**  
The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

ABBREVIATIONS	
pCi/L -	picocuries per liter (a measure of radioactivity)
ppm -	parts per million, or milligrams per liter (mg/L)
ppb -	parts per billion, or micrograms per liter (ug/L)
Avg -	Regulatory compliance with some MCLs are based on running annual average of monthly samples.